

ELLIOTT ELECTRIC SUPPLY 2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685



88HSC Wway 8X8 N1 QK Conn Conn *Cooper B-Line/Cable Tray*

| Catalog Number | 88HSC |
|------------------|---|
| Manufacturer | Cooper B-Line/Cable Tray |
| Description | Eaton B-Line Series Wireway Connector, Connector Style, |
| | Wireway Connector, Nema 1, Galvanized Steel Finish, 8" X 8" |
| Weight per unit | 0.2740 (lbs/each) |
| Product Category | Meter Socket & Metering Accy. |
| atures | |
| Cover Type | HINGED |

Fea^t

| Cover Type | HINGED |
|------------|-----------------------------------|
| dimensions | 8.0000 IN X 7.9000 IN X 8.0000 IN |
| Material | Steel |

Material, Color, and Finish

| Finish | ANSI 61 GRAY ACRYLIC ELECTROCOATED OVER WASH AND |
|--------|--|
| | DHOSDHATE LINDEDCOAT |

Dimensions and Weight

| Height | 8.00 In |
|--------|---------|
| Width | 8.00 ln |

Descriptions

| Description | WWAY 8X8 N1 QK CONN CONN |
|------------------------|---|
| extra long description | B-LINE 88 HSC HINGE SCREW CVR WIREW |
| Features | Eaton's B-Line series wiring troughs provide reliable environmental protection and are used to house runs of control and power cable in wiring, junction, pull, and termination applications. |
| Long Description | Eaton B-Line series wireway connector, Connector style, Wireway connector, NEMA 1, Galvanized steel finish, 8" X 8" |
| Product Type | Hinge Screw CVR Wireway, Connector HS 8X8 |

Manufacturer Information

| Brand | Eaton |
|---------------------------|----------------|
| GTIN | 00782051478488 |
| Manufacturers Part Number | 88 HSC |
| UPC | 782051478488 |

Taxonomies, Classifications, and Categories

| Category Description | STEEL WIRE WAY JUNCTION BOXES |
|----------------------|-------------------------------|
| Туре | Wireway connector |

Packaging

| Carton | 1 |
|-----------------|-------|
| Weight Per each | 0.274 |

ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr. 75964-0000, TX Nacogdoches Phone: 936-569-7941 Fax: 936-560-4685

Uses, Certifications, and Standards

| cs, oci micamons, ana stanac | ii do |
|------------------------------|---|
| Application | Commercial / Institutional Buildings / Structures - Commercial / Institutional Buildings / Structures - OtherInd Facilities & |
| | ŭ |
| | Factories - Facility: Critical PowerCommercial / Institutional |
| | Buildings / Structures - Safety and Security SystemsInd Facilities |
| | & Factories - Facility: Safety and Security SystemsCommercial / |
| | Institutional Buildings / Structures - Critical PowerInd Facilities & |
| | Factories - Facility: Lighting and Lighting ControlsInd Facilities & |
| | Factories - Facility: Automation and MonitoringComme |
| Enclosure | NEMA 1, IP30 |
| standard | NEMA,CSA C22.2.,UL Listed |