

ELLIOTT ELECTRIC SUPPLY 4955 Bell Springs Rd Unit 9 78620-0000, TX Dripping Springs Phone: 737-317-5073 Fax: 737-317-5074



CLGF120 Classified Gfci 1 Pole 10KAIC 20A Pigtail Neutral *Eaton Corp*

Catalog Number	CLGF120
Manufacturer	Eaton Corp
Description	Eaton Classified 1" Gfci Circuit Breaker, Ground Fault Circuit Breaker, 20 A, 10 Kaic, Single-Pole, 120/240 V, CLGF, Trip-to-Center, Plug-On, #14-8 Awg, Ground Fault Circuit Interrupter, GFI
Weight per unit	0.5000 (lbs/each)
Product Category	In Circuit Breakers
atures	
connection	Plug-on
dimensions	4.0000 IN X 3.5000 IN X 1.0000 IN
interrupt rating	10
Poles	1
Voltage Rating	120/240 V
escriptions	
Description	CLASSIFIED GFCI 1 POLE 10KAIC 20A PIGTAIL NEUTRAL
extra long description	ETN CLGF120 Classified GFCI Circuit
Features	Eaton UL classified replacement circuit breakers are available in both 3/4-inch Type CHQ and 1-inch Type CL, single- and two-po configurations. These breakers are classified as direct replacements by Underwriters Laboratories. In addition to a UL listing, they also come with a 15-year warranty.
Long Description	Eaton Classified 1" GFCI circuit breaker, Ground fault circuit
	breaker,20 A,10 kAlC,Single-pole,120/240
	V,CLGF,Trip-to-center,Plug-on,#14-8 AWG,Ground fault circuit interrupter,GFI
Product Type	Classified Gfci Circuit Breaker
anufacturer Information	
Brand	Eaton
GTIN	00786689031527
Manufacturers Part Number	CLGF120
UPC	786689031527

Category Description	Fault Sensing Breakers (AFCI/GFCI)
Type	1" GFCI circuit breakers



standard

ELLIOTT ELECTRIC SUPPLY 4955 Bell Springs Rd Unit 9 78620-0000, TX Dripping Springs Phone: 737-317-5073 Fax: 737-317-5074

Packaging	
Carton	1
Package	20
Weight Per each	0.5
Uses, Certifications, and Standards	
Application	Generation - Renewable Energy - Alternative EnergyGeneration -
	Conventional Energy - Conventional EnergyMarine Vessels and
	Equipment - Marine Vessels and Equipment - OtherDatacenters -
	IT Space: CI and Hyper ConvergedOther

Contact Manufacturer