



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685



ICS681 4 to 4 Ins Splice

Abb Installation Products, Inc

| | |
|------------------|--|
| Catalog Number | ICS681 |
| Manufacturer | Abb Installation Products, Inc |
| Description | Insulated Aluminum Service Entrance Compression Splice, #4 Awg (Acsr);#4 Awg (Stranded);#2 Awg (Solid) Conductor Size, Orange Insulation Color, 2 Conductors, 2-25/32 In Overall Length, Compression/Crimp Terminal, 600 V, 0.05 LB/Ea |
| Weight per unit | 0.0500 (lbs/each) |
| Product Category | Large Terminals & Connectors |

Features

| | |
|----------------------|-------------|
| connection | Compression |
| insulation | Yes |
| Material | Aluminum |
| Number of Conductors | 2 |

Dimensions and Weight

| | |
|------|--------------|
| Size | 2-25/32 inch |
|------|--------------|

Descriptions

| | |
|------------------------|-------------------------------------|
| Description | 4 TO 4 INS SPLICE |
| extra long description | ABB ICS68-1 AL SERV ENTR SPLICE A:2 |

Manufacturer Information

| | |
|-------|----------------------|
| Brand | Blackburn Mechanical |
| GTIN | 00783786102402 |
| UPC | 783786102402 |

Taxonomies, Classifications, and Categories

| | |
|----------------------|-------------------------------------|
| Category Description | Comp & Mech Lugs and Butt Splices |
| Type | Compression Splice Service Entrance |

Packaging

| | |
|-----------------|------|
| Carton | 100 |
| Package | 500 |
| Weight Per each | 0.05 |



ELLIOTT ELECTRIC SUPPLY

We Deliver...Lower Cost, Quality Products, & Personal Service

2310 N. Stallings Dr.
75964-0000, TX Nacogdoches
Phone: 936-569-7941
Fax: 936-560-4685

Uses, Certifications, and Standards

| | |
|--------------------------|---|
| Application | For Standard Conductor Splice |
| environmental conditions | All Seasons / Conditions |
| Mounting | None |
| standard | RUS Accepted. Complies with ANSI C119.4 when properly installed on Aluminum-to-Aluminum or Aluminum-to-Copper Conductors / RUS Accepted. Complies with ANSI C119.4 when properly installed on Aluminum-to-Aluminum or Aluminum-to-Copper Conductors |